

WATER TEST RESULTS FROM WELL AT WILSON HILL PARK
Tests Conducted by the Michigan Health Department

1. Coliform Bacteria....Non-Detectable
2. Nitrate.....Non-Detectable
3. Nitrite.....Non-Detectable
4. Chloride..... Non-Detectable
5. Fluoride.....0.4 mg/L (DL = 0.1, Max Limit is 4.0) 0.4 is good
6. Hardness..... 240 mg/L (No health limit - above 250 is hard water)
7. Iron..... 0.2 mg/L (No health limit – taste and odor above 0.3)
8. Sulfate..... 13 mg/L (DL = 3, No health limit) 13 is very good
9. Sodium.....Non-Detectable

Note: DL = The lowest amount the State can see with its analytical methodology.